

Inspection, Testing, and Maintenance of Water Storage Tanks
NFPA 25, Chapter 9 as amended by CCR, Title 19

Page 1 of 2

Date of Inspection, Testing, Maintenance: _____

Property Information:

Name: _____

Address: _____

City: _____

Abbreviation Key:

I = Inspection

T = Test

M = Maintenance

A-O = After Operation

MI = Per Manufacturer's Instructions

* = During cold weather season



Item	Activity	Frequency	Description	NFPA 25 Reference	Fail	N/A	Pass
1.1	I	Daily/Weekly*	Water temperature	9.2.4			
1.2	I	Daily/Weekly*	Heating system	9.2.6.6			
1.3	I	Monthly*	Temperature Alarms	9.2.4.2 9.2.4.3			
1.4	I	Monthly/ Quarterly*	Condition of water in tank	9.2.1			
1.5	I	Monthly/ Quarterly	Water- level	9.2.1			
1.6	I	Monthly/ Quarterly	Air Pressure	9.2.2			
1.7	I	Quarterly	Control Valves	12.3.2.1			
1.8	I	Quarterly	Tank - exterior	9.2.5.1			
1.9	I	Quarterly	Support structure	9.2.5.1			
1.10	I	Quarterly	Catwalks and ladders	9.2.5.1			
1.11	I	Quarterly	Surrounding area	9.2.5.2			
1.12	I	Annually	Hoops and grillage	9.2.5.4			
1.13	I	Annually	Painted/coated surfaces	9.2.5.5			
1.14	I	Annually	Expansion joints	9.2.5.3			
1.15	I	5 Years/3 Years	Interior	9.2.6			
1.16	I	5 Years	Check valves	12.4.2.1			
2.1	T	Monthly	Temperature Alarms	9.2.4.2 9.2.4.3			
2.2	T	Monthly*	High temperature limit switch	9.3.4			
2.3	T	Semiannually	Water level alarms	9.3.5			
2.4	T	Annually	Control Valve - Position	12.3.3.1			
2.5	T	Annually	Control Valve – Operation	12.3.3.1			
2.6	T	Annually	Supervisory	12.3.3.5			

Inspection, Testing, and Maintenance of Water Storage Tanks
NFPA 25, Chapter 9 as amended by CCR, Title 19

Page 2 of 2

Date of Inspection, Testing, Maintenance: _____

Property Information:

Name: _____

Address: _____

City: _____

Abbreviation Key:

I = Inspection

T = Test

M = Maintenance

A-O = After Operation

MI = Per Manufacturer's Instructions

* = During cold weather season



Item	Activity	Frequency	Description	NFPA 25 Reference	Fail	N/A	Pass
2.7	T	5 Years	Level indicators	9.3.1			
2.8	T	5 Years	Pressure gauges	9.3.6			
2.9	T	5 Years	Automatic filling device	9.3.7			
3.1	M	Semiannually	Drain silt	9.4.5			
3.2	M	Annually	Control valves	12.3.4			
3.3	M	----	Water level	9.4.1			
3.4	M	----	Embankment-supported coated fabric (ESCF)	9.4.6			
3.5	M	----	Check valves	12.4.2.2			

Item **Deficiencies and Comments:**
Deficiencies and Comments Item number must correspond to the Item number of the Activity listed above:

☐ See Continuation Page(s) _____ (Indicate the number of continuation pages)

☐ PASS

☐ FAIL

 Signature

 Date